



American Environmental Testing Laboratory Inc.

2834 & 2908 North Naomi Street Burbank, CA 91504 • DOHS NO: 1541, LACSD NO: 10181
Tel: (888) 288-AETL • (818) 845-8200 • Fax: (818) 845-8840 • www.aetlab.com

Ordered By

Halsey Schools
21321 Costanso Street
Woodland Hills, CA 91364-

Number of Pages 3
Date Received 02/25/2020
Date Reported 03/03/2020

Telephone: (818)518-2977
Attention: Jenni Rice

Job Number	Order Date	Client
103693	02/25/2020	HALSEY

Project ID: LEAD TESTING
Project Name: Halsey Preschool
Site: Halsey Preschool
21321 Costanso Street
Woodland Hills, CA 91364

Enclosed please find results of analyses of 1 water sample which was analyzed as specified on the attached chain of custody. If there are any questions, please do not hesitate to call.

Checked By: _____

Approved By: _____

Joe Sevrean
Laboratory Director



A KYZER LABS COMPANY

AMERICAN ENVIRONMENTAL TESTING LABORATORY

2834 NORTH NAOMI ST. BURBANK, CALIFORNIA 91504 ELAP # 1541 LACSD # 10181
TEL (888) 288-AETL (818) 845-8200 FAX (818) 845-8840 www.aetlab.com

COOLER RECEIPT FORM

Client Name: <i>Halsey Schools</i>			
Project Name:			
AETL Job Number: <i>103693</i>			
Date Received: <i>02/25/20</i>		Received by: <i>Ant</i>	
Carrier: <input checked="" type="checkbox"/> AETL Courier <input type="checkbox"/> Client <input type="checkbox"/> GSO <input type="checkbox"/> FedEx <input type="checkbox"/> UPS			
<input type="checkbox"/> Others:			
Samples were received in: <input type="checkbox"/> Cooler () <input checked="" type="checkbox"/> Other (Specify):			
Inside temperature of shipping container No 1: , No 2: , No 3:			
Type of sample containers: <input type="checkbox"/> VOA, <input type="checkbox"/> Glass bottles, <input type="checkbox"/> Wide mouth jars, <input checked="" type="checkbox"/> HDPE bottles, <input type="checkbox"/> Metal sleeves, <input type="checkbox"/> Others (Specify):			
How are samples preserved: <input checked="" type="checkbox"/> None, <input type="checkbox"/> Ice, <input type="checkbox"/> Blue Ice, <input type="checkbox"/> Dry Ice			
<input checked="" type="checkbox"/> None, <input type="checkbox"/> HNO ₃ , <input type="checkbox"/> NaOH, <input type="checkbox"/> ZnOAc, <input type="checkbox"/> HCl, <input type="checkbox"/> Na ₂ S ₂ O ₃ , <input type="checkbox"/> MeOH			
<input type="checkbox"/> Other (Specify):			
	Yes	No, explain below	Name, if client was notified.
1. Are the COCs Correct?	<i>Y</i>		
2. Are the Sample labels legible?	<i>Y</i>		
3. Do samples match the COC?	<i>Y</i>		
4. Are the required analyses clear?	<i>Y</i>		
5. Is there enough samples for required analysis?	<i>Y</i>		
6. Are samples sealed with evidence tape?		<i>N</i>	
7. Are sample containers in good condition?	<i>Y</i>		
8. Are samples preserved?		<i>Y</i>	
9. Are samples preserved properly for the intended analysis?	<i>Y</i>		
10. Are the VOAs free of headspace?	<i>N/A</i>		
11. Are the jars free of headspace?	<i>Y</i>		

PLEASE NOTE ALL SAMPLES WILL BE DISPOSED OF 30 DAYS AFTER RECEIVING DATE. IF AETL IS INFORMED OTHERWISE, THERE WILL BE A STORAGE CHARGE PER SAMPLE PER MONTH FOR ANY SAMPLE HELD BEYOND 30 DAYS.

Explain all "No" answers for above questions:



American Environmental Testing Laboratory Inc.

2834 & 2908 North Naomi Street Burbank, CA 91504 • DOHS NO: 1541, LACSD NO: 10181

Tel: (888) 288-AETL • (818) 845-8200 • Fax: (818) 845-8840 • www.aetlab.com

Page: 1 A

Ordered By

Halsey Schools
21321 Costanso Street
Woodland Hills, CA 91364-

Project ID: LEAD TESTING
Date Received 02/25/2020
Date Reported 03/03/2020

Telephone: (818) 518-2977
Attention: Jenni Rice

Job Number	Order Date	Client
103693	02/25/2020	HALSEY

CERTIFICATE OF ANALYSIS CASE NARRATIVE

AETL received 1 samples with the following specification on 02/25/2020.

Lab ID	Sample ID	Sample Date	Matrix	Quantity Of Containers	
103693.01	Preschool	02/25/2020	Aqueous	1	
Method ^	Submethod	Req Date	Priority	TAT	Units
200.8	PB	03/03/2020	2	Normal	ug/L

The samples were analyzed as specified on the enclosed chain of custody. No analytical non-conformances were encountered.

Under Safe Drinking Water Act, EPA set the action level for Lead in drinking water at 15 ug/L. All Result in this report is below the action level.

Checked By:

Approved By:

Joe Sevran
Laboratory Director



American Environmental Testing Laboratory Inc.

2834 & 2908 North Naomi Street Burbank, CA 91504 • DOHS NO: 1541, LACSD NO: 10181
 Tel: (888) 288-AETL • (818) 845-8200 • Fax: (818) 845-8840 • www.aetlab.com

ANALYTICAL RESULTS

Ordered By

Halsey Schools
 21321 Costanso Street
 Woodland Hills, CA 91364-

Site

Halsey Preschool
 21321 Costanso Street
 Woodland Hills, CA 91364

Telephone: (818)518-2977

Attn: Jenni Rice

Page: 2

Project ID: LEAD TESTING
 Project Name: Halsey Preschool

AETL Job Number	Submitted	Client
103693	02/25/2020	HALSEY

Method: 200.8, Lead by ICP/MS

QC Batch No: 0226202C3

Our Lab I.D.		Method Blank	103693.01			
Client Sample I.D.			Preschool			
Date Sampled			02/25/2020			
Date Prepared		02/26/2020	02/26/2020			
Preparation Method		200.8	200.8			
Date Analyzed		02/26/2020	02/26/2020			
Matrix		Aqueous	Aqueous			
Units		ug/L	ug/L			
Dilution Factor		1	1			
Analytes	MDL	PQL	Results	Results		
Lead	0.5	1.0	ND	1.93		



American Environmental Testing Laboratory Inc.

2834 & 2908 North Naomi Street Burbank, CA 91504 • DOHS NO: 1541, LACSD NO: 10181
 Tel: (888) 288-AETL • (818) 845-8200 • Fax: (818) 845-8840 • www.aetlab.com

QUALITY CONTROL RESULTS

Ordered By

Halsey Schools
 21321 Costanso Street
 Woodland Hills, CA 91364-

Site

Halsey Preschool
 21321 Costanso Street
 Woodland Hills, CA 91364

Telephone: (818)518-2977

Attn: Jenni Rice

Page: 3

Project ID: LEAD TESTING
 Project Name: Halsey Preschool

AETL Job Number	Submitted	Client
103693	02/25/2020	HALSEY

Method: 200.8, Lead by ICP/MS

QC Batch No: 0226202C3; Dup or Spiked Sample: 103712.01; LCS: Clean Water; QC Prepared: 02/26/2020; QC Analyzed: 02/26/2020;
 Units: ug/L

Analytes	Sample Result	MS Concen	MS Recov	MS % REC	MS DUP Concen	MS DUP Recov	MS DUP % REC	RPD %	MS/MSD % Limit	MS RPD % Limit
Lead	2.50	10.0	11.8	93.0	10.0	11.8	93.0	<1	80-120	<15

QC Batch No: 0226202C3; Dup or Spiked Sample: 103712.01; LCS: Clean Water; QC Prepared: 02/26/2020; QC Analyzed: 02/26/2020;
 Units: ug/L

Analytes	LCS Concen	LCS Recov	LCS % REC	LCS DUP Concen	LCS DUP Recov	LCS DUP % REC	LCS RPD % REC	LCS/LCSD % Limit	LCS RPD % Limit
Lead	10.0	9.90	99.0	10.0	10.2	102	3.0	80-120	<15



American Environmental Testing Laboratory Inc.

2834 & 2908 North Naomi Street, Burbank, CA 91504 • DOHS NO: 1541, LACSD NO: 10181
Tel: (888) 288-AETL • (818) 845-8200 • Fax: (818) 845-8840 • www.aetlab.com

Data Qualifiers and Descriptors

Data Qualifier:

- #: Recovery is not within acceptable control limits.
- *: In the QC section, sample results have been taken directly from the ICP reading. No preparation factor has been applied.
- B: Analyte was present in the Method Blank.
- D: Result is from a diluted analysis.
- E: Result is beyond calibration limits and is estimated.
- H: Analysis was performed over the allowed holding time due to circumstances which were beyond laboratory control.
- J: Analyte was detected . However, the analyte concentration is an estimated value, which is between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL).
- M: Matrix spike recovery is outside control limits due to matrix interference. Laboratory Control Sample recovery was acceptable.
- MCL: Maximum Contaminant Level
- NS: No Standard Available
- S6: Surrogate recovery is outside control limits due to matrix interference.
- S8: The analysis of the sample required a dilution such that the surrogate concentration was diluted below the method acceptance criteria.
- X: Results represent LCS and LCSD data.

Definition:

- %Limi: Percent acceptable limits.
- %REC: Percent recovery.
- Con.L: Acceptable Control Limits
- Conce: Added concentration to the sample.
- LCS: Laboratory Control Sample
- MDL: Method Detection Limit is a statistically derived number which is specific for each instrument, each method, and each compound. It indicates a distinctively detectable quantity with 99% probability.



American Environmental Testing Laboratory Inc.

2834 & 2908 North Naomi Street, Burbank, CA 91504 • DOHS NO: 1541, LACSD NO: 10181
Tel: (888) 288-AETL • (818) 845-8200 • Fax: (818) 845-8840 • www.aetlab.com

Data Qualifiers and Descriptors

MS:	Matrix Spike
MS DU:	Matrix Spike Duplicate
ND:	Analyte was not detected in the sample at or above MDL.
PQL:	Practical Quantitation Limit or ML (Minimum Level as per RWQCB) is the minimum concentration that can be quantified with more than 99% confidence. Taking into account all aspects of the entire analytical instrumentation and practice.
Recov:	Recovered concentration in the sample.
RPD:	Relative Percent Difference
